



**EN DATE DU 24 JUILLET 2017
AS OF JULY 24th 2017**



**INDICES DE LA QUALITÉ DE L'EAU
POUR LA BAINNADE**



WATER QUALITY INDEX FOR SWIMMING

BON



GOOD

PASSABLE



FAIR

MÉDIOCRE



POOR

FERMÉ



CLOSED

**Veuillez noter que ces résultats reflètent seulement la qualité de l'eau testée au parc de l'Aboiteau.
Please note that these results reflect only the water quality tested at Aboiteau Beach.**

150, allée du Parc, Cap-Pelé, NB E4N 1S4.

Report ID: 243263-ML-W1
Report Date: 26-Jul-17
Date Received: 25-Jul-17

CERTIFICATE OF ANALYSIS

for
Village de Cap-Pele
2647 chemin Acadie
Cap-Pele, NB E4N 1C2



921 College Hill Rd
Fredericton NB
Canada E3B 6Z9
Tel: 506.452.1368
Fax: 506.452.1395
www.rpc.ca

Attention: Julie Arseneau / Stephane Dallaire /
Brett Tryon / Diane Fury / Doris Whalen
P/O #: 34602

Project/Job #: 34602

Client Location: Aboiteau Beach

Microbiological Examination of Water

Analytes:				Enterococcus	E. coli
Units:				MPN/100mL	MPN/100mL
Method ID:				FFA35	FFA01
Date Analyzed:				25-Jul-17	25-Jul-17
RPC Sample ID	Client Sample ID	Date Sampled	Time Sampled		
243263-1	Swimming Water West #1	24-Jul-17	11:50:00 AM	<10	10
243263-2	Swimming Water #2	24-Jul-17	11:53:00 AM	<10	10
243263-3	Swimming Water #3	24-Jul-17	11:57:00 AM	<10	<10
243263-4	Swimming Water #4	24-Jul-17	12:07:00 PM	<10	10
243263-5	Swimming Water East #5	24-Jul-17	12:11:00 PM	<10	20

This report relates only to the sample(s) and information provided to the laboratory.

Tests were performed according to the corresponding Compendium of Analytical Methods,
Health Protection Branch and/or AOAC Official Methods.

Cathy Hay
Microbiology Supervisor
Food, Fisheries & Aquaculture

Gillian Hodges
Microbiology Technician
Food, Fisheries & Aquaculture